



# Conceptual Designs for Thermal, Cold, and Very Cold Neutron Moderator Systems for CANS

Rolando Granada

*Centro Atómico Bariloche, CNEA,  
ARGENTINA*



Comisión Nacional  
de Energía Atómica



Research article

---

# Conceptual moderator designs for compact neutron sources

JR Granada<sup>1</sup>

<https://doi.org/10.1177/10238166241299259>

Journal of Neutron Research

1–25

© The Author(s) 2024

Article reuse guidelines:

[sagepub.com/journals-permissions](https://sagepub.com/journals-permissions)

DOI: 10.1177/10238166241299259



[journals.sagepub.com/home/jne](https://journals.sagepub.com/home/jne)

 Sage |  IOS Press



Comisión Nacional  
de Energía Atómica

## THE CHALLENGE (or part of it)




Spectrum of neutrons from the 100 K liquid methane moderator of IPNS.  
 (Carpenter & Loong, *Elements of Neutron Scattering*, Cambridge 2015)



# The slowing-down parameters for several typical protonated moderators.

Parameter	H <sub>2</sub> O	(CH <sub>2</sub> ) <sub>n</sub>	C <sub>2</sub> H <sub>6</sub>	C <sub>2</sub> H <sub>6</sub>	CH <sub>4</sub>	CH <sub>4</sub>	C <sub>9</sub> H <sub>12</sub>	H <sub>2</sub>
	293 K	293 K	180 K	100 K	100 K	20 K	20 K	16K
$\sigma_{\text{free}}$ (barn)	44.749	45.73	132.46	132.46	86.73	86.73	288.69	20.505
$\rho$ (g/cm <sup>3</sup> )	1	0.94	0.550	0.641	0.4392	0.510	0.91	0.0751
$N^{\text{molec}}$ (10 <sup>24</sup> /cm <sup>3</sup> )	0.0335	0.0404	0.0110	0.0129	0.0165	0.0192	0.0046	0.0226
$N^{\text{H}}$ (10 <sup>22</sup> /cm <sup>3</sup> )	6.69	8.09	6.63	7.72	6.61	7.68	5.48	4.52
$\Sigma_{\text{free}}$ (cm <sup>-1</sup> )	1.5	1.849	1.463	1.705	1.431	1.665	1.318	0.927
$\xi$	0.926	0.913	0.940	0.940	0.954	0.954	0.876	1
$\gamma$	0.924	0.908	0.936	0.936	0.951	0.951	0.976	1
$v t_s$ (cm)	2.105	1.723	2.135	1.832	2.162	1.858	2.58	3.235
$v \Delta t_s$ (cm)	1.183	0.963	1.205	1.034	1.227	1.055	1.476	1.867
$v \Delta t_{1/2}$ (cm)	2.346	1.915	2.383	2.046	2.421	2.080	2.897	3.65

The time distribution of neutrons slowing-down past 1 eV in water (normalized).



## Thermalization parameters for some hydrogenous moderators.

Parameter	H <sub>2</sub> O 293 K	(CH <sub>2</sub> ) <sub>n</sub> 293 K	C <sub>2</sub> H <sub>6</sub> 180 K	C <sub>2</sub> H <sub>6</sub> 100 K	CH <sub>4</sub> 100 K	CH <sub>4</sub> 20 K
$\alpha_0$ (s <sup>-1</sup> )	4898	5821	4860	5650	4868	5654
$D_0$ (cm <sup>2</sup> s <sup>-1</sup> )	38415	27130	19140	10794	17110	6011
$C$ (cm <sup>4</sup> s <sup>-1</sup> )	2838	2422	590	184	650	80
$\lambda_{tr}$ (cm)	0.47	0.26	0.30	0.23	0.36	0.28

Decay constant:  $\alpha \approx \alpha_0 + D_0 B^2 - C B^4$


Geometrical Buckling:  $B^2$ , Diffusion Constant:  $D_0$ , Cooling Constant:  $C$

Evaluation of thermalization parameters:

<https://doi.org/10.1103/PhysRevA.36.5585>



The FWHM of the neutron pulse as a function of wavelength.



# TN, CN, & VCN MODERATOR CONCEPTS FOR HiCANS

## Motivation:





To develop basic concepts for the moderator complex of HiCANS, assuming that they may include thermal (TN), cold (CN), and very cold (VCN) neutron sources.

## Components and Materials





- ✓ Target Square (10x10 cm)
- ✓ TN moderator material: H<sub>2</sub>O, PLE (RT) / C<sub>2</sub>H<sub>6</sub> (100K - 180K)
- ✓ CN moderator material: Liquid *para*-H<sub>2</sub> (20K)
- ✓ VCN moderator material: Solid (4K) CH<sub>4</sub> II
- ✓ Premoderator material: H<sub>2</sub>O
- ✓ CN & VCN reflectors: MgH<sub>2</sub> / ND
- ✓ Fast neutron reflector: Be (long tail) or Pb (faster)





# Thermal Moderators





# Cold Moderators



# Very Cold Moderators



(w. JI Marquez Damián)



## TN+CN concept

This concept corresponds to a moderator system able to produce 4 beams of TN and 4 beams of CN.

## TN+CN+VCN concepts

A second concept also includes provision of a VCN beam. The latter is based on a Methane (II) moderator at 4K.

A third concept includes high intensity TN, CN, and VCN beams.

A fourth concept is a variant of concept 3, but includes only high intensity CN and VCN beams.

Thin platform (3 cm): High brilliance  
Thick platform (6 cm): High intensity





## Concept 1. TN + CN - High Brightness

- ◆ Low-dimensional **CN** moderators (3x3x14 cm) – para H<sub>2</sub>
  - 4 beams with best coupling to the thermal source*
  - Use of CN reflector (MgH<sub>2</sub>) to minimize leakage from CN to TN regions.*
- ◆ Fast, intense **TN** moderator (Reentrant, 3x3x1.5 cm) – H<sub>2</sub>O
  - 4 beams using Reentrant holes to extract thermal neutrons from the highest thermal flux region.*
  - Thermal source optimally coupled to the fast and epithermal (from the premods) neutron sources*

*MERIT: High brightness CN beams; intense TN pulse*





4 TN  
4 hb CN




## Concept 2. TN + CN + VCN – High Brightness

- ◆ Low-dimensional **CN** moderators (3x3x14 cm) – **para H<sub>2</sub>**  
*4 beams with best coupling to the thermal source*  
*Use of CN reflector (MgH<sub>2</sub>) to minimize leakage from CN to TN regions.*
- ◆ Small (fast) **VCN** moderator (3x3x1.5 cm) – **solid CH<sub>4</sub> (II)**  
*2 beams with best coupling to the thermal source, achieved by placing the VCN moderator at the bottom of a reentrant hole of 2.7 cm in depth*
- ◆ Fast, intense **TN** moderator (Reentrant, 3x3x1.5 cm) – **H<sub>2</sub>O**  
*1 beam using Reentrant hole to extract thermal neutrons from the highest thermal flux region.*  
*1 beam from a very fast thermal moderator (decoupled).*



**MERIT: High brightness CN beams; fast TN pulse; fast VCN beam**





2 TN (1 very fast)  
 4 hb CN  
 2 VCN





- 3 TN (1 very fast)
- 2 hb CN
- 2 VCN
- 1 CN+VCN





### Concept 3. TN + CN + VCN – High Intensity

- ◆ Semi Low-dimensional **CN** moderators (3x6x14 cm) – para H2  
*4 intense beams with best coupling to the thermal source*  
*Use of CN reflector (MgH2) to minimize leakage from CN to TN regions.*
- ◆ Large **VCN** moderator (1.5 cm thick,  $\Phi = 6$  cm) – solid CH4 (II)  
*1 beam with best coupling to the thermal source, achieved by placing the VCN moderator at the bottom of a reentrant hole of 3 cm in depth*
- ◆ Large **TN** moderator (Reentrant hole, 3 cm depth,  $\Phi = 6$  cm) – H2O  
*1 beam using Reentrant hole to extract thermal neutrons from the highest thermal flux region.*  
*Thermal source optimally coupled to the fast and epithermal (from the premods) neutron sources.*


**MERIT: Intense CN beams; Very intense TN beam; Intense VCN beam**






1 TN (very int.)  
 4 hi CN  
 1 VCN (very int.)






THERMAL POOL:  
H2O (1:1) D2O



- 1 TN (very int.)
- 3 hi CN
- 1 VCN (very int.)
- 1 TN+CN





THERMAL POOL:  
H<sub>2</sub>O (1:1) D<sub>2</sub>O



- 1 TN (very int.)
- 1 CN
- 2 VCN (very int.)
- 1 TN+CN
- 1 CN+VCN



OTHER COMBINATIONS...










- 1 TN (very int.)
- 1 CN+VCN
- 2 VCN (very int.)







- 1 TN (very int.)
- 2 hi-hb CN
- 1 VCN (very int.)










# A CONFIGURATION FOR MiCANS





# A CONFIGURATION FOR MiCANS





# A CONFIGURATION FOR MiCANS



# A CONFIGURATION FOR MiCANS



# A CONFIGURATION FOR MiCANS



## CONCLUSIONS

Compact moderators, and in particular low-dimensional moderators are very well suited for CANS.

Conceptual geometries were presented to motivate simulations aimed at the optimization of different spectral beam characteristics. The dimensions proposed are compatible with the HBS target.

These concepts are oriented to the production of thermal, cold, and very cold neutron beams, either of high brilliance or high intensity types.

The concepts presented here are only indicative of the different combination of thermalized sources that can be arranged for each target station.



THANKS FOR YOUR ATTENTION!



